

TEST REPORT

TO: City of Lincoln City
P. O. Box 50
Lincoln City, OR 97367

12/16/2016

CITLIN

PO#: 27508

Collection Information

Date: 11/15/2016
Time: 0800
By: Stryker
Lab #: 20161116-037
Location: A *4th Floor City Hall*

Lab Receipt Information

11/16/2016
1217
MH

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead Schools/Bldgs	SM3113 B	A	ND		0.001	mg/l	0.020	12/12/2016	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The EPA Level of 0.015 mg/liter (or ppm) also listed as 15 ppb is an ACTION LEVEL, NOT A SAFE HEALTH STANDARD. There is NO safe level of lead in drinking water. This Action Level does NOT mean that waters with lower levels are safe.

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: *Bette E. Myers*

TEST REPORT

TO: City of Lincoln City
P. O. Box 50
Lincoln City, OR 97367

12/16/2016

CITLIN

PO#: 27508

Collection Information

Date: 11/15/2016
Time: 0800
By: Stryker
Lab #: 20161116-038
Location: B *CITY HALL EMPLOYEE LUNCH ROOM*

Lab Receipt Information

11/16/2016
1217
MH

Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA	Analysis	
							Limit	Date Time	Tech
Lead Schools/Bldgs	SM3113 B	A	0.0011		0.001	mg/l	0.020	12/12/2016	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

* Accreditation

A- Waterlab Corporation, ORELAP 100039

The EPA Level of 0.015 mg/liter (or ppm) also listed as 15 ppb is an ACTION LEVEL, NOT A SAFE HEALTH STANDARD. There is NO safe level of lead in drinking water. This Action Level does NOT mean that waters with lower levels are safe.

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: *Bette E. Myers*